

Motor-protective circuit-breaker, 3p, 16A, inside the enclosure

Powering Business Worldwide*

Part no. PKZM01-16-G
Article no. 286089
Catalog No. XTPB016BC1ENCS65

Design verification as per IEC/EN 61439

besign vermoution as per 120/214 01-103			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	16
Equipment heat dissipation, current-dependent	P _{vid}	W	6.43
Heat dissipation capacity	P _{diss}	W	0
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 5.0

Low-voltage industrial components (EG000017) / Motor protective circuit-breaker (EC000074)						
Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker motor protection (ecl@ss8-27-37-04-01 [AGZ529012])						
Setting range overload protector	Α	10 - 16				
Adjustment range undelayed short-circuit release	А	248 - 248				
Phase failure sensitive		Yes				
Switch off technique		Thermomagnetic				
Rated operating voltage	V	690 - 690				
Rated permanent current lu	Α	16				
Rated operation power at AC-3, 230 V	kW	4				
Rated operation power at AC-3, 400 V	kW	7.5				
Connection type main current circuit		Screw connection				
Device construction		Complete device in housing				
With integrated auxiliary switch		No				
With integrated under voltage release		No				

Number of poles			3
Rated short-circuit breaking capacity Icu at 400 V, AC	k/	£Α	50
Degree of protection (IP)			IP65