



Residual current circuit breaker (RCCB), 25A, 4 p, 500mA, type AC

Part no. PF7-25/4/05
Article no. 165811
Catalog No. PDC-TBD6068

Similar to illustration

Design verification as per IEC/EN 61439

| Technical data for design verification | | | | |
|--|-----------|---|--|--|
| Rated operational current for specified heat dissipation | I_n | A | | 25 |
| Equipment heat dissipation, current-dependent | P_{vid} | W | | 2.8 |
| IEC/EN 61439 design verification | | | | |
| 10.2 Strength of materials and parts | | | | |
| 10.2.2 Corrosion resistance | | | | |
| | | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | | |
| | | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | | |
| | | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | | |
| | | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | | |
| | | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | | |
| | | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | | |
| | | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | | |
| | | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | | |
| | | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | | |
| | | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | | |
| | | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | | |
| | | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | | |
| | | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | | |
| | | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | | |
| 10.9.2 Power-frequency electric strength | | | | |
| | | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | | |
| | | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | | |
| | | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | | |
| | | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | | |
| | | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | | |
| | | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | | |
| | | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 5.0

| Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003) | | | | |
|--|--|----|--|----------------|
| Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ec1@ss8-27-14-22-01 [AAB906010]) | | | | |
| Number of poles | | | | 4 |
| Rated voltage | | V | | 230 |
| Rated current | | A | | 25 |
| Rated fault current | | A | | 0.5 |
| Mounting method | | | | DIN-rail (DRA) |
| Leakage current type | | | | AC |
| Selective protection | | | | No |
| Short-circuit breaking capacity (I_{cw}) | | kA | | 10 |
| Rated short-circuit breaking capacity EN 60898 | | kA | | 0.5 |
| Rated short-circuit breaking capacity IEC 60947-2 | | kA | | 0 |
| Surge current capacity | | kA | | 0.25 |
| Frequency | | | | 50 Hz |

| | | | |
|--|--|----|------|
| Additional equipment possible | | | Yes |
| Degree of protection (IP) | | | IP20 |
| Construction size (in accordance with DIN 43880) | | | 1 |
| Width in number of modular spacings | | | 4 |
| Built-in depth | | mm | 69.5 |
| Short-time delayed tripping | | | No |