

Over current switch, 40A, 3 p, type C characteristic

PL4-C40/3 293164



Similar to illustration

Design verification as per IEC/EN 61439

Part no.

Article no.

Reted operational current for specified heat dissipation In A A A A Equipment heat dissipation, current-dependent Pvd W 11.2 IECEEN 61439 design verification Mets the product standard's requirements. Mets the product standard's requirements. 10.2.3.1 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects Mets the product standard's requirements. 10.2.3.2.3.1 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Mets the product standard's requirements. 10.2.3.2.4.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1	Technical data for design verification			
Equipment heat dissipation, current-dependent Ped Paid W EEU/EN 61438 design verification 12 102.2 Corrosion resistance Meets the product standard's requirements. 102.3.1 Verification of thormal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 102.4 Resistance to ultra-viole (UV) rediation Meets the product standard's requirements. 102.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 102.6 Corropration of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 103.6 Incorporation for switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 104.7 Heart and vertified of more switchgear needs to be evaluated. Dees not apply, since the entire switchgear needs to be evaluated. </td <td>-</td> <td>1</td> <td>٨</td> <td>40</td>	-	1	٨	40
Interpretation Interpretation 102 Strength of materials and parts Meets the product standard's requirements. 102.2 Corrision resistance Meets the product standard's requirements. 102.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.3 La Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.3 La Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.3 La Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.3 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.3 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 103.4 Clearances and creepage distances Meets the product standard's requirements. 104.5 Entrapie Does not apply, since the entire switchgear needs to be evaluated. 105.7 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 105.7 Incorporation for external conductors<				
102.Strength of materials and parts Meets the product standard's requirements. 102.2.2 Corrosion resistance Meets the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Meets the product standard's requirements. 103.8 Degree of protection of ASSEMBLIES Dees not apply, since the entire switchgear needs to be evaluated. 104.1 Clearances and creepage distances Meets the product standard's requirements. 105.8 Incerporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 105.9 Protection against electric al circuits and connections Is the panel builder's responsibility. 108.2 Power-frequency electric strength Is the panel builder's responsibility. 109.3 Insulation properties Is the panel builder's responsibility. 109.3 Insulation strength Is the panel builder's responsibility. 109.1 Thereal electrical circuits and oonnections		Pvid	vv	11.2
10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects Meets the product standard's requirements. 10.23.4 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.24 Resistance to ultra-violet (UV) radiation Does not apply, since the entire switchgear needs to be evaluated. 10.25 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.25 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.25 Protection against electric strength Is the panel builder's responsibility. 10.25 Protection against electric strength Is the panel builder's responsibility. 10.25 Protection against electric strength Is the panel builder's responsibility. 10.29 Insulation properties Is the panel builder's responsibility. 10.29 Insulation properties Is the panel builder's responsibility. 10.21 Thermal electric a connections Is the panel builder's responsibility. 10.29 Insulation properties Is the panel builder's responsibility. 10.2	.			
102.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Urifing Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and components Does not apply, since the entire switchgear needs to be evaluated. 10.9 Insulation properties Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Thermal electrical strongth Is the panel builder's responsibility. 10.9.2 The panel builde	10.2 Strength of materials and parts			
102.2.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical inpact Does not apply, since the entire switchgear needs to be evaluated. 103.0 Egree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Neuron electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.1 Thermal electric rating Is the panel builder's responsibility. 10.9.2 Power-frequency electric streng	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Entite switchgear needs to be evaluated. 10.9 Insulation properties Entite switchgear needs to be evaluated. 10.9.1 Short-circuit rating Entite switchgear needs to be evaluated. 10.13 Mechanical function Entite switchgear needs to be evaluated. 10.13 Mechanical function Entite switchgear needs to be evaluated. 10.8 Incorporation of switching devices and components Entite switchgear needs to be evaluated. 10.9 Insulation properties Is the panel builde	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effectsAdd fire due to internal electric effects10.2.4 Resistance to ultra-violet (UV) radiationMeets the product standard's requirements.10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.8 Connections for external conductorsStep panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.1 Substand voltageIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.1 Stort-circuit ratingIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibility.Is the panel builder's responsibility. The specifications for the switchgear must dossrved.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.1 Neutation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.1 Short-circuit ratingIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must to observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must to observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must to observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must to observed.				Meets the product standard's requirements.
10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must doserved. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must doserved. 10.13 Mechanical function It he avice mee	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.1 Thermate of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.13 Mechanical function	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Supulse withstand voltage Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must I observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must I observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must boserved. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must boserved. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must fobserved. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must fobserved. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation propertiesImage: Constraint of the second sec	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must to observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must hobserved. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must hobserved. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must hobserved. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must hobserved. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must hobserved. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must hobserved. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must hobserved. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise			
10.13 Mechanical function observed.	10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.13 Mechanical function			

Technical data ETIM 5.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8-27-14-19-01 [AAB905010])

Release characteristic		C
Number of poles (total)		3
Rated current	А	40
Rated voltage	V	400
Rated short-circuit breaking capacity EN 60898	kA	4.5
Rated short-circuit breaking capacity IEC 60947-2	kA	A 0
Voltage type		AC
Current limiting class		3
Frequency	Hz	z 50
Concurrently switching N-neutral		No
Over voltage category		3

Pollution degree		2
Width in number of modular spacings		3
Built-in depth	mm	70.5
Additional equipment possible		Yes
Degree of protection (IP)		IP20