



Over current switch, 13A, 3 p, type C characteristic

Part no. PL6-C13/3
Article no. 286600

Similar to illustration

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-----------|---|--|
| Rated operational current for specified heat dissipation | I_n | A | 13 |
| Equipment heat dissipation, current-dependent | P_{vid} | W | 7.8 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 5.0

| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042) | | | |
|--|--|----|-----|
| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8-27-14-19-01 [AAB905010]) | | | |
| Release characteristic | | | C |
| Number of poles (total) | | | 3 |
| Rated current | | A | 13 |
| Rated voltage | | V | 400 |
| Rated short-circuit breaking capacity EN 60898 | | kA | 6 |
| Rated short-circuit breaking capacity IEC 60947-2 | | kA | 0 |
| Voltage type | | | AC |
| Current limiting class | | | 3 |
| Frequency | | Hz | 50 |
| Concurrently switching N-neutral | | | No |
| Over voltage category | | | 3 |

| | | | |
|-------------------------------------|--|----|------|
| Pollution degree | | | 2 |
| Width in number of modular spacings | | | 3 |
| Built-in depth | | mm | 70.5 |
| Additional equipment possible | | | Yes |
| Degree of protection (IP) | | | IP20 |